


序号	报告编号	发布日期	结论	影像资料
88	GX-B1328/20-6-25132	2025年6月5日	本次共检验绝缘胶垫150块，150块绝缘胶垫合格。	 <p>2025 05 13</p>
89	GX-B1328/20-6-25133	2025年6月5日	本次共检验绝缘胶垫50块，50块绝缘胶垫合格。	 <p>2025 05 12</p>


90	GX-B1328/20-6-25134	2025年6月5日	本次共检验绝缘胶垫3块，3块绝缘胶垫合格。		
91	GX-B1310/21-6-25161	2025年6月6日	符合标准要求		
92	GX-B1310/21-6-25162	2025年6月6日	符合标准要求		

93	GX-B1310/21-6-25163	2025年6月6日	符合标准要求		
94	GX-B1310/21-6-25164	2025年6月6日	符合标准要求		
95	GX-B1427/21-6-25039	2025年6月6日	符合标准要求		

96	GX-B1427/21-6-25040	2025年6月6日	符合标准要求		 <p>2025 04 22</p>	
97	GX-B1427/21-6-25041	2025年6月6日	符合标准要求		 <p>2025 04 21</p>	
98	GX-B1427/21-6-25042	2025年6月6日	符合标准要求		 <p>2025 04 22</p>	

99	GX-B1598/24-6-25053	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为3.16%，小于5%为正常。			
100	GX-B1598/24-6-25054	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为2.44%，小于5%为正常。			
101	GX-B1598/24-6-25055	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为2.37%，小于5%为正常。			

102	GX-B1598/24-6-25056	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为2.35%，小于5%为正常。	
103	GX-B1598/24-6-25057	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为2.97%，小于5%为正常。	
104	GX-B1598/24-6-25058	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为2.71%，小于5%为正常。	

105	GX-B1598/24-6-25059	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.43%，小于5%为正常。	
106	GX-B1598/24-6-25060	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.58%，小于5%为正常。	
107	GX-B1598/24-6-25061	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.56%，小于5%为正常。	

108	GX-B1598/24-6-25062	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.68%，小于5%为正常。	
109	GX-B1598/24-6-25063	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.18%，小于5%为正常。	
110	GX-B1598/24-6-25064	2025年6月6日	实测钢丝绳有效截面积损失百分比最大为0.24%，小于5%为正常。	

111	GX-B1495/20-6-25634~25638	2025年6月4日	本次共检高压开关柜5台，5台高压开关柜所检项目合格。	 <p>2025 04 22</p>
112	GX-B1495/20-6-251085~251100	2025年6月5日	本次共检高压开关柜10台，10台高压开关柜所检项目合格。	 <p>2025 04 22</p>
113	GX-B1495/20-6-251101~251118	2025年6月5日	本次共检高压防爆开关16台，16台高压防爆开关所检项目合格。	 <p>2025 04 21</p>

114	GX-B1495/20-6-251075~251084	2025年6月5日	本次共检高压开关柜18台，18台高压开关柜所检项目合格。	 <p>2025 04 21</p>
115	GX-B1323/21-6-25096~25101	2025/6/5	所检项目合格。	 <p>2025 04 20</p>
116	GX-B1323/21-6-25102~25113	2025/6/5	所检项目合格。	 <p>2025 04 23</p>

117	GX-B1323/21-6-25114~25118	2025/6/5	所检项目合格。	
118	GX-B1323/21-6-25119~25127	2025/6/5	所检项目合格。	
119	GX-B1323/21-6-25128~25130	2025/6/5	所检项目合格。	

120	GX-B1323/21-6-25131~25138	2025/6/5	所检项目合格。	
121	GX-B1323/21-6-25139~25140	2025/6/5	所检项目合格。	
122	GX-B1321/20-6-25544~25551	2025/6/4	本次共检电力电缆8条，8条电力电缆所检项目合格。	

123	GX-B1321/20-6-25552~25559	2025/6/4	本次共检电力电缆8条，8条电力电缆所检项目合格。	
124	GX-B1321/20-6-25560~25568	2025/6/4	本次共检电力电缆9条，9条电力电缆所检项目合格。	
125	GX-B1522/-2500032TH1	2025年6月10日	所检项目合格	

126	GX-B1522/-2500033TH1	2025年6月10日	所检项目合格	
127	GX-B1328/20-6-25151	2025年6月10日	本次共检绝缘手套4只, 4只绝缘手套合格。	
128	GX-B1328/20-6-25152	2025年6月10日	本次共检全橡胶绝缘胶靴4只, 4只全橡胶绝缘胶靴合格。	

129	GX-B1350/21-6-25025	2025. 6. 10	所检项目合格。	 A worker in a blue uniform and red helmet is standing and using a handheld electronic device. The device is connected to a cable. The background shows an indoor setting with a doorway. A timestamp '2025 05 07' is visible in the bottom right corner of the photo.
130	GX-B1350/21-6-25026	2025. 6. 10	所检项目合格。	 A worker in a blue uniform and red helmet is kneeling on the floor, working on a wall. He is using a tool to work on a hole in the wall. A green object is visible on the wall. A timestamp '2025 05 08' is visible in the bottom right corner of the photo.
131	GX-B1350/21-6-25027	2025. 6. 10	所检项目合格。	 A worker in a blue uniform and red helmet is kneeling on a concrete surface, possibly a roof or a platform. He is using a tool to work on a hole in the concrete. A metal railing is visible in the background. A timestamp '2025 05 09' is visible in the bottom right corner of the photo.

132	GX-B1350/21-6-25028	2025. 6. 10	所检项目合格。		
133	GX-B1611/23-6-25001	2025年6月10日	所检项目合格		
134	GX-B1309/21-6-25024	2025. 6. 11	所检项目合格。		

135	GX-B1500/21-6-25109	2025. 6. 11	综合判定：合格。		 <p>2025 06 10</p>	
136	GX-B1500/21-6-25110	2025. 6. 11	综合判定：合格。		 <p>2025 06 10</p>	
137	GX-B1500/21-6-25111	2025. 6. 11	综合判定：合格。		 <p>2025 06 10</p>	

138	GX-B1500/21-6-25112	2025. 6. 11	综合判定：合格。	 <p>2025 05 10</p>	
139	GX-B1309/21-6-25025	2025. 6. 11	所检项目合格。	 <p>2025 05 10</p>	
140	GX-B1500/21-6-25113	2025. 6. 11	综合判定：合格。	 <p>2025 05 10</p>	

141	GX-B1500/21-6-25114	2025. 6. 11	综合判定：合格。		
142	GX-B1500/21-6-25115	2025. 6. 11	综合判定：合格。		
143	GX-B1309/21-6-25026	2025. 6. 11	所检项目合格。		

144	GX-B1500/21-6-25116	2025. 6. 11	综合判定：合格。		
145	GX-B1500/21-6-25117	2025. 6. 11	综合判定：合格。		
146	GX-B1500/21-6-25118	2025. 6. 11	综合判定：合格。		

147	GX-B1500/21-6-25119	2025. 6. 11	综合判定：合格。	 <p>2025.05.10</p>	
148	GX-B1309/21-6-25027	2025. 6. 11	所检项目合格。	 <p>2025.05.11</p>	
149	GX-B1500/21-6-25120	2025. 6. 11	综合判定：合格。	 <p>2025.05.11</p>	

150	GX-B1500/21-6-25121	2025.6.11	综合判定：合格。		
151	GX-B1500/21-6-25122	2025.6.11	综合判定：合格。		
152	GX-B1309/21-6-25028	2025.6.11	所检项目合格。		

153	GX-B1500/21-6-25123	2025. 6. 11	综合判定：合格。		
154	GX-B1500/21-6-25124	2025. 6. 11	综合判定：合格。		
155	GX-B1500/21-6-25125	2025. 6. 11	综合判定：合格。		

156	GX-B1309/21-6-25024	2025. 6. 11	所检项目合格。		 <p>2025. 05. 10</p>	
157	GX-B1500/21-6-25109	2025. 6. 11	综合判定：合格。		 <p>2025. 05. 10</p>	
158	GX-B1500/21-6-25110	2025. 6. 11	综合判定：合格。		 <p>2025. 05. 10</p>	

159	GX-B1500/21-6-25111	2025. 6. 11	综合判定：合格。		
160	GX-B1500/21-6-25112	2025. 6. 11	综合判定：合格。		
161	GX-B1309/21-6-25025	2025. 6. 11	所检项目合格。		


162	GX-B1500/21-6-25113	2025. 6. 11	综合判定：合格。		
163	GX-B1500/21-6-25114	2025. 6. 11	综合判定：合格。		
164	GX-B1500/21-6-25115	2025. 6. 11	综合判定：合格。		

165	GX-B1309/21-6-25026	2025. 6. 11	所检项目合格。		
166	GX-B1500/21-6-25116	2025. 6. 11	综合判定：合格。		
167	GX-B1500/21-6-25117	2025. 6. 11	综合判定：合格。		


168	GX-B1500/21-6-25118	2025. 6. 11	综合判定：合格。		
169	GX-B1500/21-6-25119	2025. 6. 11	综合判定：合格。		
170	GX-B1309/21-6-25027	2025. 6. 11	所检项目合格。		

171	GX-B1500/21-6-25120	2025. 6. 11	综合判定：合格。		
172	GX-B1500/21-6-25121	2025. 6. 11	综合判定：合格。		
173	GX-B1500/21-6-25122	2025. 6. 11	综合判定：合格。		



174	GX-B1309/21-6-25028	2025. 6. 11	所检项目合格。		
175	GX-B1500/21-6-25123	2025. 6. 11	综合判定：合格。		
176	GX-B1500/21-6-25124	2025. 6. 11	综合判定：合格。		


177	GX-B1500/21-6-25125	2025. 6. 11	综合判定：合格。			
178	GX-B1328/20-6-25117	2025年6月10日	本次共检绝缘手套101只，101只绝缘手套合格。			
179	GX-B1328/20-6-25118	2025年6月10日	本次共检绝缘手套33只，33只绝缘手套合格。			

180	GX-B1328/20-6-25119	2025年6月10日	本次共检验电器16支，16支验电器合格。	
181	GX-B1328/20-6-25120	2025年6月10日	本次共检验携带式接地和接地短路装置3组，3组携带式接地和接地短路装置合格。	
182	GX-B1328/20-6-25121	2025年6月10日	本次共检绝缘手套80只，80只绝缘手套合格。	

183	GX-B1328/20-6-25122	2025年6月10日	本次共检绝缘手套72只，72只绝缘手套合格。			
184	GX-B1328/20-6-25123	2025年6月10日	本次共检绝缘手套36只，36只绝缘手套合格。			
185	GX-B1328/20-6-25124	2025年6月10日	本次共检绝缘手套24只，24只绝缘手套合格。			

186	GX-B1328/20-6-25125	2025年6月10日	本次共检绝缘手套12只，12只绝缘手套合格。	
187	GX-B1328/20-6-25126	2025年6月10日	本次共检全橡胶绝缘胶靴14只，14只全橡胶绝缘胶靴合格。	
188	GX-B1328/20-6-25127	2025年6月10日	本次共检全橡胶绝缘胶靴26只，26只全橡胶绝缘胶靴合格。	

189	GX-B1328/20-6-25128	2025年6月10日	<p>本次共检全橡胶绝缘胶靴2只，2只全橡胶绝缘胶靴合格。</p> <p>。</p>			
190	GX-B1328/20-6-25129	2025年6月10日	<p>本次共检验电器2支，2支验电器合格。</p>			
191	GX-B1328/20-6-25130	2025年6月10日	<p>本次共检验便携式接地和接地短路装置2组，2组便携式接地和接地短路装置合格。</p>			

192	GX-B1328/20-6-25131	2025年6月10日	本次共检验绝缘杆2组，2组绝缘杆合格。 。			
-----	---------------------	------------	--------------------------	--	---	--