


序号	报告编号	发布日期	结论	影像资料	
1	GX-B1499/23-7-25032	2025. 6. 3	综合判定：合格。		
2	GX-B1499/23-7-25033	2025. 6. 3	综合判定：合格。		

3	GX-B1332/21-7-25043~25048	2025. 6. 3	本次共检电力电容器6台，6台电力电容器所检项目合格。	
4	GX-B1329/21-7-25045~25048	2025. 6. 3	本次共检氧化锌避雷器4组，4组氧化锌避雷器所检项目合格。	
5	GX-B1321/20-7-25078~25079	2025. 6. 3	本次共检电力电缆2条，2条电力电缆所检项目合格。	

6	GX-B1321/20-7-25316~25317	2025. 6. 3	本次共检电力电缆2条，2条电力电缆所检项目合格。 。	 2025/03/08
7	GX-B1321/20-7-25318~25319	2025. 6. 3	本次共检电力电缆2条，2条电力电缆所检项目合格。 。	 2025/03/08
8	GX-B1312/20-7-25065~25068	2025. 6. 3	本次共检电力变压器4台，4台电力变压器所检项目合格。	 2025/03/07

9	GX-B1312/20-7-25363~25366	2025. 6. 3	本次共检电力变压器 4台，4台电力变压器所检 项目合格。	
10	GX-B1312/20-7-25367	2025. 6. 3	所检项目合格。	
11	GX-B1336/22-7-25009	2025. 6. 3	所检项目合格。	

12	GX-B1336/22-7-25010	2025. 6. 3	所检项目合格。	
13	GX-B1495/20-7-25800~25811	2025. 6. 3	本次共检高压开关柜 12台，12台高压开关柜所 检项目合格。	
14	GX-B1495/20-7-251087~251097	2025. 6. 3	本次共检高压开关设备11 台，11台高压开关设备所 检项目合格。	

15	GX-B1495/20-7-251098~251103	2025. 6. 3	本次共检高压开关设备6台，6台高压开关设备所检项目合格。	
16	GX-B1332/21-7-25049~25054	2025. 6. 3	本次共检电力电容器6台，6台电力电容器所检项目合格。	
17	GX-B1495/20-7-251160~251165	2025/6/3	本次共检高压防爆开关6台，6台高压防爆开关所检项目合格。	


18	GX-B1321/20-7-25461~25470	2025/6/3	本次共检电力电缆10条，10条电力电缆所检项目合格。	
19	GX-B1321/20-7-25450~25460	2025/6/3	本次共检电力电缆11条，11条电力电缆所检项目合格。	
20	GX-B1321/20-7-25478~25482	2025/6/3	本次共检电力电缆5条，5条电力电缆所检项目合格。	

21	GX-B1321/20-7-25471~25477	2025/6/3	本次共检电力电缆7条，7条电力电缆所检项目合格。 。	 2025/4/21
22	GX-B1321/20-7-25395~25402	2025/6/3	本次共检电力电缆8条，8条电力电缆所检项目合格。 。	 2025/4/21
23	GX-B1321/20-7-25386~25394	2025/6/3	本次共检电力电缆9条，9条电力电缆所检项目合格。 。	 2025/4/20

24	GX-B1321/20-7-25564~25566	2025/6/3	本次共检电力电缆3条，3条电力电缆所检项目合格。 。	
25	GX-B1321/20-7-25567~25570	2025/6/3	本次共检电力电缆4条，4条电力电缆所检项目合格。 。	
26	GX-B1321/20-7-25350~25364	2025/6/3	电缆15条，15条电力电缆所	


27	GX-B1321/20-7-25365~25379	2025/6/3	电缆15条，15条电力电缆所	
28	GX-B1359/21-7-25099~25112	2025/6/4	本次共检矿用隔爆型照明 信号综合保护装置 14台, 14台所检项目合格。 。	
29	GX-B1359/21-7-25113~25116	2025/6/4	本次共检矿用隔爆型照明 信号综合保护装置4台, 4 台所检项目合格。	



30	GX-B1359/21-7-25117~25121	2025/6/4	本次共检矿用隔爆型照明信号综合保护装置5台, 5台所检项目合格。	
31	GX-B1359/21-7-25122	2025/6/4	所检项目合格。	
32	GX-B1352/21-7-25223~25235	2025/6/4	本次共检矿用防爆低压交流真空馈电开关13台, 13台所检项目合格。	

33	GX-B1352/21-7-255151~255163	2025/6/4	本次共检矿用防爆低压交流真空馈电开关漏电保护13台, 13台所检项目合格。 。		
34	GX-B1352/21-7-25236~25247	2025/6/4	本次共检矿用防爆低压交流真空馈电开关12台, 12台所检项目合格。		
35	GX-B1352/21-7-255164~255175	2025/6/4	本次共检矿用防爆低压交流真空馈电开关漏电保护12台, 12台所检项目合格。 。		


36	GX-B1352/21-7-25248~25263	2025/6/4	本次共检矿用防爆低压交流真空馈电开关16台, 16台所检项目合格。	
37	GX-B1352/21-7-255176~255191	2025/6/4	本次共检矿用防爆低压交流真空馈电开关漏电保护16台, 16台所检项目合格。 。	
38	GX-B1352/21-7-25264~25274	2025/6/4	本次共检矿用防爆低压交流真空馈电开关11台, 11台所检项目合格。	

39	GX-B1352/21-7-255192~255202	2025/6/4	本次共检矿用防爆低压交流真空馈电开关漏电保护11台, 11台所检项目合格。 。	
40	GX-B1352/21-7-25275~25288	2025/6/4	本次共检矿用防爆低压交流真空馈电开关14台, 14台所检项目合格。	
41	GX-B1352/21-7-255203~255216	2025/6/4	本次共检矿用防爆低压交流真空馈电开关漏电保护14台, 14台所检项目合格。 。	


42	GX-B1350/21-7-25020	2025/6/4	本次共检验接地装置 6处，6处所检项目全部合格。			
43	GX-B1350/21-7-25021	2025/6/4	本次共检验接地装置 7处，7处所检项目全部合格。			
44	GX-B1350/21-7-25022	2025/6/4	本次共检验接地装置 4处，4处所检项目全部合格。			

45	GX-B1350/21-7-25023	2025/6/4	本次共检验接地装置 7处，7处所检项目全部合格。			
46	GX-B1350/21-7-25024	2025/6/4	本次共检验接地装置 4处，4处所检项目全部合格。			
47	GX-B1350/21-7-25026	2025/6/4	本次共检验接地装置 8处，8处所检项目全部合格。			


48	GX-B1350/21-7-25027	2025/6/4	本次共检验接地装置 2处，2处所检项目全部合格。	
49	GX-B1495/25-7-251057~251067	2025. 6. 4	所检项目合格。	
50	GX-B1495/25-7-251068~251086	2025. 6. 4	所检项目合格。	


51	GX-B1495/25-7-251128~251131	2025. 6. 4	所检项目合格。	
52	GX-B1495/25-7-251132	2025. 6. 4	所检项目合格。	
53	GX-B1312/20-7-25344~25349	2025. 6. 4	所检项目合格。	



54	GX-B1312/20-7-25350~25354	2025. 6. 4	所检项目合格。	
55	GX-B1312/20-7-25355~25362	2025. 6. 4	所检项目合格。	
56	GX-B1329/21-7-25064~25081	2025. 6. 4	所检项目合格。	

57	GX-B1321/20-7-25311~25315	2025. 6. 4	所检项目合格。	
58	GX-B1354/20-7-25007	2025. 6. 4	所检项目合格。	
59	GX-B1350/21-7-25016	2025. 6. 4	本次共检验接地装置 12处，12处所检项目合格。 。	

60	GX-B1350/21-7-25017	2025. 6. 4	本次共检验接地装置5处，5处所检项目合格。	
61	GX-B1354/20-7-25008	2025. 6. 5	合格。	
62	GX-B1352/21-7-25140~25150	2025. 6. 5	本次共检矿用防爆低压交流真空馈电开关11台, 11台所检项目合格。	

63	GX-B1352/21-7-255070~255080	2025. 6. 5	本次共检矿用防爆低压交流真空馈电开关漏电保护11台, 11台所检项目合格。 。		 A worker in a red safety suit and helmet is standing next to a piece of industrial equipment. The worker is wearing a red helmet with a headlamp and a red jacket with reflective stripes. The equipment is dark and has some wires attached to it. The date 2025/4/24 is visible in the bottom right corner of the image.
64	GX-B1352/21-7-255081~255085	2025. 6. 5	本次共检矿用防爆低压交流真空馈电开关漏电保护5台, 5台所检项目合格。		 A worker in a red safety suit and helmet is working on a piece of industrial equipment. The worker is wearing a red helmet with a headlamp and a red jacket with reflective stripes. The equipment is dark and has some wires attached to it. The date 2025/4/24 is visible in the bottom right corner of the image.
65	GX-B1359/21-7-25060~25067	2025. 6. 5	本次共检矿用隔爆型照明信号综合保护装置8台, 8台所检项目合格。		 A worker in a red safety suit and helmet is working on a piece of industrial equipment. The worker is wearing a red helmet with a headlamp and a red jacket with reflective stripes. The equipment is dark and has some wires attached to it. The date 2025/4/24 is visible in the bottom right corner of the image.

66	GX-B1328/20-7-25036	2025. 6. 3	本次共检绝缘鞋52只，52只绝缘鞋合格。	 2025.3.22
67	GX-B1328/20-7-25035	2025. 6. 3	本次共检绝缘手套52只，52只绝缘手套合格。	 2025.3.22
68	GX-B1312/20-7-25305~25308	2025. 6. 3	本次共检电力变压器4台，4台电力变压器所检项目合格。	 2025.3.20

69	GX-B1312/20-7-25380~25388	2025. 6. 3	本次共检电力变压器 9台，9台电力变压器所检 项目合格。	
70	GX-B1350/21-7-25018	2025/6/5	本次共检验接地装置 18处，18处所检项目全部 合格。	
71	GX-B1350/21-7-25019	2025/6/5	本次共检验接地装置 6处，6处所检项目全部合 格。	

72	GX-B1350/21-7-25010	2025. 6. 4	本次共检验接地装置 12处，12处所检项目合格。 。			
73	GX-B1350/21-7-25011	2025. 6. 4	本次共检验接地装置 13处，13处所检项目合格。 。			