



序号	报告编号	发布日期	结论	影像资料
83	GX-B1404/20-P-25020	2025. 7. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求。	 2025.6.23
84	GX-B1404/20-P-25021	2025. 7. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求。	 2025.6.23
85	GX-B1404/20-P-25022	2025. 7. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993《电能质量 公用电网谐波》要求。	 2025.6.23

86	GX-B1328/20-P-25093	2025. 7. 14	本次共检绝缘手套 32只，32只绝缘手 套合格。	 2025.6.29
87	GX-B1328/20-P-25094	2025. 7. 14	本次共检绝缘鞋26 只，26只绝缘鞋合 格。	 2025.6.29
88	GX-B1328/20-P-25097	2025. 7. 14	本次共检验电器 6支，6支验电器合 格。	 2025.6.29


89	GX-B1328/20-P-25095	2025. 7. 14	本次共检携带式接地和接地短路装置9套，9套携带式接地和接地短路装置合格。	 2025.6.29
90	GX-B1328/20-P-25096	2025. 7. 14	本次共检绝缘杆18套，18套绝缘杆合格。	 2025.6.29
91	GX-B1312/20-P-25415~25417	2025. 7. 10	本次共检电力变压器3台，3台电力变压器所检项目合格。 。	 2025.6.14

92	GX-B1312/20-P-25418~25419	2025. 7. 10	本次共检电力变压器2台，2台电力变压器所检项目合格。 。		
93	GX-B1312/20-P-25420	2025. 7. 10	所检项目合格。		
94	GX-B1312/20-P-25421~25423	2025. 7. 10	本次共检电力变压器3台，3台电力变压器所检项目合格。 。		

95	GX-B1312/20-P-25424	2025. 7. 10	所检项目合格。	 2025.6.18
96	GX-B1323/21-P-25221~25224	2025. 7. 10	所检项目合格。	 2025.6.15
97	GX-B1323/21-P-25225~25226	2025. 7. 10	所检项目合格。	 2025.6.15

98	GX-B1323/21-P-25227~25228	2025. 7. 10	所检项目合格。	
99	GX-B1323/21-P-25229	2025. 7. 10	所检项目合格。	
100	GX-B1321/20-P-25755~25758	2025. 7. 11	本次共检电力电缆4条，4条电力电缆所检项目合格。	

101	GX-B1321/20-P-25759~25764	2025. 7. 11	本次共检电力电缆6条，6条电力电缆所检项目合格。	 2025.6.16
102	GX-B1321/20-P-25765~25768	2025. 7. 11	本次共检电力电缆4条，4条电力电缆所检项目合格。	 2025.6.17
103	GX-B1495/25-P-251983~251989	2025. 7. 11	本次共检高压开关设备7台，7台高压开关设备所检项目合格。	 2025.6.14

104	GX-B1495/25-P-251990~251991	2025. 7. 11	本次共检高压开关设备2台，2台高压开关设备所检项目合格。	
105	GX-B1495/25-P-251992~251999	2025. 7. 11	本次共检高压开关设备8台，8台高压开关设备所检项目合格。	
106	GX-B1495/25-P-252000~252001	2025. 7. 11	本次共检高压开关设备2台，2台高压开关设备所检项目合格。	

107	GX-B1495/25-P-252002~252009	2025. 7. 11	本次共检防爆型高压配电装置8台，8台防爆型高压配电装置所检项目合格。		
108	GX-B1495/25-P-252010~252020	2025. 7. 11	本次共检防爆型高压配电装置11台，11台防爆型高压配电装置所检项目合格。		
109	GX-B1495/25-P-252021~252027	2025. 7. 11	本次共检高压开关设备7台，7台高压开关设备所检项目合格。		

110	GX-B1495/25-P-252028	2025. 7. 11	所检项目合格。	 A photograph showing two workers in a substation aisle. One worker is holding a red tool or device. The date stamp '2025.6.18' is visible in the bottom right corner of the image.
111	GX-B1321/20-P-25769	2025. 7. 17	所检项目合格。	 A photograph of a worker in a substation wearing a red hard hat and holding a laptop. The date stamp '2025.6.14' is visible in the bottom right corner of the image.
112	GX-B1495/25-P-252065~252066	2025. 7. 17	本次共检互感器 2组，2组互感器所 检项目合格。	 A photograph of a worker in a substation wearing a red hard hat, kneeling and inspecting a substation cabinet. The date stamp '2025.6.14' is visible in the bottom left corner of the image.

113	GX-B1495/25-P-252058~252064	2025. 7. 17	本次共检高压开关柜7台，7台高压开关柜所检项目合格。 。	
-----	-----------------------------	-------------	---------------------------------	---