




序号	报告编号	发布日期	结论	影像资料
42	GX-B1329/21-5-25264~25285	2025. 8. 11	本次共检氧化锌避雷器22组，22组所检项目合格。	
43	GX-B1495/25-5-251195~251199	2025. 8. 11	本次共检高压开关柜5台，5台高压开关柜所检项目合格。	


44	GX-B1310/21-5-25208	2025. 8. 11	符合标准要求。	
45	GX-B1310/21-5-25209	2025. 8. 11	符合标准要求。	

46	GX-B1310/21-5-25210	2025. 8. 11	符合标准要求。	
47	GX-B1310/21-5-25211	2025. 8. 11	符合标准要求。	
48	GX-B1310/21-5-25212	2025. 8. 11	符合标准要求。	

49	GX-B1312/20-5-25702~25704	2025. 8. 11	本次共检防爆干式变压器3台，3台防爆干式变压器所检项目合格。	
50	GX-B1404/20-5-25027	2025. 8. 11	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
51	GX-B1624/24-5-25001	2025. 8. 9	详细结果见报告内页。 。	

52	GX-B1624/24-5-25003	2025. 8. 9	详细结果见报告内页。 。			
53	GX-B1624/24-5-25002	2025. 8. 9	详细结果见报告内页。 。			
54	GX-B1624/24-5-25004	2025. 8. 9	详细结果见报告内页。 。			

55	GX-B1313/21-5-25098~25104	2025. 8. 13	本次共检电力变压器7台，7台电力变压器所检项目合格。	 2025/5/30
56	GX-B1313/21-5-25105~25112	2025. 8. 13	本次共检电力变压器8台，8台电力变压器所检项目合格。	 2025/6/1

57	GX-B1313/21-5-25113~25118	2025. 8. 13	本次共检电力变压器6台，6台电力变压器所检项目合格。	
58	GX-B1313/21-5-25119~25121	2025. 8. 13	本次共检电力变压器3台，3台电力变压器所检项目合格。	

59	GX-B1313/21-5-25122~25126	2025. 8. 13	本次共检电力变压器5台，5台电力变压器所检项目合格。	
60	GX-B1451/20-5-25607~25621	2025. 8. 11	本次共检高压开关柜15台，15台高压开关柜所检项目合格。	

61	GX-B1451/20-5-25622~25634	2025. 8. 11	本次共检高压开关柜13台，13台高压开关柜所检项目合格。	 2025/6/1
62	GX-B1451/20-5-25635~25640	2025. 8. 11	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	 2025/6/2

63	GX-B1451/20-5-25641~25646	2025. 8. 11	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	
64	GX-B1451/20-5-25647~25664	2025. 8. 11	本次共检高压开关柜18台，18台高压开关柜所检项目合格。	

65	GX-B1451/20-5-25665~25674	2025. 8. 11	本次共检高压开关柜10台，10台高压开关柜所检项目合格。	
66	GX-B1451/20-5-25675~25691	2025. 8. 11	本次共检高压开关柜17台，17台高压开关柜所检项目合格。	

67	GX-B1451/20-5-25692~25698	2025. 8. 11	本次共检高压开关柜7台，7台高压开关柜所检项目合格。	
68	GX-B1451/20-5-25699~25711	2025. 8. 11	本次共检高压开关柜13台，13台高压开关柜所检项目合格。	

69	GX-B1451/20-5-25712~25722	2025. 8. 11	本次共检高压开关柜11台，11台高压开关柜所检项目合格。	 2025/6/3
70	GX-B1319/21-5-25007`25021	2025. 8. 12	本次共检高压交流断路器15台，15台高压交流断路器所检项目合格。	 2025/5/29

71	GX-B1319/21-5-25022`25036	2025. 8. 12	本次共检高压交流断路器15台，15台高压交流断路器所检项目合格。	 2025/6/1
72	GX-B1319/21-5-25037`25042	2025. 8. 12	本次共检高压交流断路器6台，6台高压交流断路器所检项目合格。	 2025/6/2

73	GX-B1319/21-5-25043`25048	2025. 8. 12	本次共检高压交流断路器6台，6台高压交流断路器所检项目合格。	 2025/6/3
74	GX-B1319/21-5-25049`25066	2025. 8. 12	本次共检高压交流断路器18台，18台高压交流断路器所检项目合格。	 2025/5/29

75	GX-B1319/21-5-25067`25076	2025. 8. 12	本次共检高压交流断路器10台，10台高压交流断路器所检项目合格。	
76	GX-B1319/21-5-25077`25093	2025. 8. 12	本次共检高压交流断路器17台，17台高压交流断路器所检项目合格。	

77	GX-B1319/21-5-25094`25100	2025. 8. 12	本次共检高压交流断路器7台，7台高压交流断路器所检项目合格。	
78	GX-B1319/21-5-25101`25113	2025. 8. 12	本次共检高压交流断路器13台，13台高压交流断路器所检项目合格。	

79	GX-B1319/21-5-25114`25124	2025. 8. 12	本次共检高压交流断路器11台，11台高压交流断路器所检项目合格。	
80	GX-B1451/20-5-25445~25459	2025. 8. 8	本次共检高压开关柜15台，15台高压开关柜所检项目合格。	

81	GX-B1451/20-5-25460~25472	2025. 8. 8	本次共检高压开关柜13台，13台高压开关柜所检项目合格。	
82	GX-B1451/20-5-25473~25478	2025. 8. 8	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	

83	GX-B1451/20-5-25479~25484	2025. 8. 8	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	
84	GX-B1451/20-5-25485~25502	2025. 8. 8	本次共检高压开关柜18台，18台高压开关柜所检项目合格。	

85	GX-B1451/20-5-25503~25512	2025. 8. 8	本次共检高压开关柜10台，10台高压开关柜所检项目合格。	
86	GX-B1451/20-5-25513~25529	2025. 8. 8	本次共检高压开关柜17台，17台高压开关柜所检项目合格。	

87	GX-B1451/20-5-25530~25536	2025. 8. 8	本次共检高压开关柜7台，7台高压开关柜所检项目合格。	
88	GX-B1451/20-5-25537~25549	2025. 8. 8	本次共检高压开关柜13台，13台高压开关柜所检项目合格。	

89	GX-B1451/20-5-25550~25560	2025. 8. 8	本次共检高压开关柜11台，11台高压开关柜所检项目合格。	
----	---------------------------	------------	------------------------------	---