



序号	报告编号	发布日期	结论	影像资料
90	GX-B1495/25-5-251188~251193	2025. 8. 13	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	
91	GX-B1495/25-5-251194	2025. 8. 13	所检项目合格。	
92	GX-B1328/20-5-25164	2025. 8. 14	本次共检绝缘手套8只，8只绝缘手套合格。	


93	GX-B1328/20-5-25165	2025. 8. 14	本次共检绝缘靴8只，8只绝缘靴合格。	 2025/8/5
94	GX-B1312/20-5-25705	2025. 8. 15	所检项目合格。	 2025/7/22
95	GX-B1495/25-5-251203~251213	2025. 8. 15	本次共检高压开关柜11台，11台高压开关柜所检项目合格。	 2025/7/22

96	GX-B1322/21-5-25225~25237	2025. 8. 22	本次共检电力电缆13条，13条电力电缆所检项目合格。	
97	GX-B1322/21-5-25238~25248	2025. 8. 22	本次共检电力电缆11条，11条电力电缆所检项目合格。	
98	GX-B1451/20-5-25723~25744	2025. 8. 22	本次共检高压开关柜22台，22台高压开关柜所检项目合格。	


99	GX-B1451/20-5-25745~25760	2025. 8. 22	本次共检高压开关柜16台, 16台高压开关柜所检项目合格。	
100	GX-B1451/20-5-25761~25775	2025. 8. 22	本次共检高压开关柜15台, 15台高压开关柜所检项目合格。	
101	GX-B1451/20-5-25776~25791	2025. 8. 25	本次共检高压开关柜16台, 16台高压开关柜所检项目合格。	
102	GX-B1451/20-5-25792~25811	2025. 8. 22	本次共检高压开关柜20台, 20台高压开关柜所检项目合格。	

103	GX-B1451/20-5-25812~25826	2025. 8. 22	本次共检高压开关柜15台, 15台高压开关柜所检项目合格。	
104	GX-B1324/21-5-25001~25003	2025. 8. 20	所检项目合格。	

105	GX-B1328/20-5-25131	2025. 8. 20	本次共检绝缘手套 42只，42只绝缘手套合格。	
106	GX-B1328/20-5-25132	2025. 8. 20	本次共检绝缘靴42只， 42只绝缘靴合格。	

107	GX-B1328/20-5-25133	2025. 8. 20	本次共检验电器15支， 15支验电器合格。	
108	GX-B1328/20-5-25134	2025. 8. 20	本次共检携带式接地和 接地短路装置9套，9套 携带式接地和接地短路 装置合格。	

109	GX-B1328/20-5-25172	2025. 8. 20	本次共检绝缘杆4个，4个绝缘杆合格。	 A man wearing a red jacket and dark pants stands outdoors on a paved surface. He is positioned next to a piece of electrical testing equipment, which includes a black case with various wires and a digital display. A yellow date stamp '2025/6/23' is visible in the bottom right corner of the photo.
110	GX-B1313/21-5-25127~25135	2025. 8. 21	本次共检电力变压器9台，9台电力变压器所检项目合格。	 A man wearing a red safety helmet, safety glasses, and a grey work shirt with orange safety harness is kneeling inside an open electrical cabinet. He is working on a set of red and black electrical wires. A yellow date stamp '2025/6/19' is visible in the bottom right corner of the photo.


111	GX-B1313/21-5-25136~25139	2025. 8. 21	本次共检电力变压器4台，4台电力变压器所检项目合格。	
112	GX-B1328/20-5-25162	2025. 8. 18	本次共检绝缘手套30只，30只绝缘手套合格。	
113	GX-B1328/20-5-25163	2025. 8. 18	本次共检绝缘靴30只，30只绝缘靴合格。	

114	GX-B1328/20-5-25166	2025. 8. 18	本次共检接地线10个， 10个接地线合格。	
115	GX-B1328/20-5-25167	2025. 8. 18	本次共检验电器10只， 10只验电器合格。	
116	GX-B1328/20-5-25168	2025. 8. 21	本次共检绝缘手套 20只，20只绝缘手套合 格。	

117	GX-B1328/20-5-25169	2025. 8. 21	本次共检绝缘靴20只， 20只绝缘靴合格。	
118	GX-B1328/20-5-25170	2025. 8. 21	本次共检接地线6个，6 个接地线合格。	
119	GX-B1328/20-5-25171	2025. 8. 21	本次共检验电器10只， 10只验电器合格。	

120	GX-B1323/21-5-25125~25127	2025. 8. 24	所检项目合格。		
121	GX-B1323/21-5-25128	2025. 8. 24	所检项目合格。		
122	GX-B1321/20-5-25730~25734	2025. 8. 20	本次共检电力电缆 5条，5条电力电缆所检 项目合格。		

123	GX-B1495/25-5-251214~251218	2025. 8. 21	本次共检高压开关柜5台，5台高压开关柜所检项目合格。		
124	GX-B1312/20-5-25706	8. 21	所检项目合格。		
125	GX-B1323/21-5-25118~25121	2025. 8. 20	所检项目合格。		

126	GX-B1323/21-5-25122~25123	2025. 8. 20	所检项目合格。	
127	GX-B1495/25-5-251200~251202	2025. 8. 20	本次共检六氟化硫封闭式组合电器3台，3台所检项目合格。	
128	GX-B1300/23-5-25019	2025/8/19	综合判定：合格	

129	GX-B1300/23-5-25023	2025/8/19	综合判定：合格	
130	GX-B1300/23-5-25024	2025/8/19	综合判定：合格	
131	GX-B1310/21-5-25226	2025/8/22	符合标准要求。	

132	GX-B1310/21-5-25227	2025/8/22	符合标准要求。	
-----	---------------------	-----------	---------	---