

序号	报告编号	发布日期	结论	影像资料
1	GX-B1451/20-1-26041~26044	2026. 2. 2	本次共检高压开关柜4台, 4台高压开关柜所检项目合格。	
2	GX-B1495/25-1-26029~26039	2026. 2. 2	本次共检高压开关柜11台, 11台高压开关柜所检项目合格。	

3	GX-B1495/25-1-26040~26054	2026. 2. 2	本次共检高压开关柜15台，15台高压开关柜所检项目合格。	 <p>2026/1/19</p>
4	GX-B1312/20-1-26012~26016	2026. 2. 2	本次共检电力变压器5台，5台电力变压器所检项目合格。	 <p>2026/1/19</p>

5	GX-B1495/25-1-26055~26066	2026. 2. 2	本次共检高压开关设备12台，12台高压开关设备所检项目合格。			
6	GX-B1428/21-1-26011	2026. 2. 2	无缺陷痕迹显示。			

7	GX-B1495/25-1-26024~26028	2026. 2. 2	本次共检高压开关设备5台，5台高压开关设备所检项目合格。 。	
8	GX-B1350/21-1-26003	2026. 2. 2	本次共检接地装置8处，8处所检项目合格。 。	

9	GX-B1350/21-1-26005	2026. 2. 2	本次共检接地装置 7处，7处接地装置所 检项目合格。		
10	GX-B1321/20-1-26012~26020	2026. 2. 2	本次共检电力电缆 9条，9条电力电缆所 检项目合格。		

11	GX-B1350/21-1-26004	2026. 2. 2	本次共检接地装置 3处，3处接地装置所 检项目合格。	 <p>2026.1.19</p>
12	GX-B1322/21-1-26030~26032	2026. 2. 2	本次共检验电力电缆3 条，3条所检项目合格 。	 <p>2026.1.21</p>

13	GX-B1321/20-1-26001~26007	2026. 2. 3	本次共检电力电缆 7条，7条电力电缆所 检项目合格。	
14	GX-B1312/20-1-26003~26005	2026. 2. 3	本次共检电力变压器3 台，3台电力变压器所 检项目合格。	

15	GX-B1359/21-1-26001~26006	2026. 2. 4	本次共检矿用隔爆型照明信号综合保护装置6台,6台所检项目合格。		
16	GX-B1352/21-1-26001~26016	2026. 2. 3	本次共检矿用防爆低压交流真空馈电开关16台,16台所检项目合格。		

17	GX-B1323/26-1-26001~26003	2026. 2. 5	本次共检防爆交流电动机3台，3台防爆交流电动机所检项目合格	
18	GX-B1301/25-1-26002	2026. 2. 5	综合判定:合格	

19	GX-B1309/21-1-26001	2026. 2. 6	所检项目合格			
20	GX-B1500/21-1-26010	2026. 2. 6	综合判定：合格			

21	GX-B1500/21-1-26011	2026. 2. 6	综合判定：合格		 <p>2026/01/28</p>
22	GX-B1500/21-1-26012	2026. 2. 6	综合判定：合格		 <p>2026/01/28</p>

23	GX-B1316/23-1-26013	2026. 2. 6	所检项目合格	
24	GX-B1316/23-1-26014	2026. 2. 6	所检项目合格	

25	GX-B1316/23-1-26015	2026. 2. 6	所检项目合格		
26	GX-B1308/23-1-26001	2026. 2. 6	综合判定：合格		

27	GX-B1499/23-1-26001	2026. 2. 6	所检项目合格	
28	GX-B1499/23-1-26002	2026. 2. 6	所检项目合格	

29	GX-B1499/23-1-26003	2026. 2. 6	所检项目合格		
30	GX-B1427/21-1- 26008	2026. 2. 6	符合标准要求		

31	GX-B1427/21-1- 26009	2026. 2. 6	符合标准要求	
32	GX-B1428/21-1- 26005	2026. 2. 6	无缺陷痕迹显示	

33	GX-B1428/21-1- 26007	2026. 2. 6	无缺陷迹痕显示	
34	GX-B1515/22-1-26001	2026. 2. 5	所检项目合格。	

35	GX-B1598/24-1-26003	2026. 2. 6	实测钢丝绳有效截面积损失百分比最大为3.62%，小于5%为正常		
36	GX-B1598/24-1-26004	2026. 2. 6	实测钢丝绳有效截面积损失百分比最大为3.27%，小于5%为正常		

37	GX-B1598/24-1-26005	2026. 2. 6	实测钢丝绳有效截面积损失百分比最大为3.32%，小于5%为正常	 <p>2026/01/29</p>
38	GX-B1322/21-1-26033~26043	2026. 2. 9	本次共检验电力电缆11条，11条所检项目合格。	 <p>2026.2.3</p>

39	GX-B1310/21-1-26002	2026. 2. 9	符合标准要求	
40	GX-B1310/21-1-26003	2026. 2. 9	符合标准要求	

41	GX-B1310/21-1-26004	2026. 2. 9	符合标准要求	
42	GX-B1310/21-1- 26006	2026. 2. 9	符合标准要求	

43	GX-B1301/25-1-26001	46062	综合判定：合格。	
44	GX-B1321/20-1-26021~26029	2026. 2. 10	本次共检电力电缆 9条，9条电力电缆所 检项目合格	

45	GX-B1314/21-1-26001~26004	2026. 2. 10	本次共检煤矿在用干式电抗器4台，4台煤矿在用干式电抗器所检项目合格	
46	GX-B1495/25-1-26067~26070	2026. 2. 10	本次共检高压开关柜4台，4台高压开关柜所检项目合格	

47	GX-B1312/20-1-26017~26018	2026. 2. 10	本次共检电力变压器2台，2台电力变压器所检项目合格	
48	GX-B1329/21-1-26001~26025	2026. 2. 10	本次共检过电压保护器25台，25台过电压保护器所检项目合格	

49	GX-B1382/26-1-26001	2026. 2. 10	综合判定：合格	
50	GX-B1310/21-1-26013	2026/2/10	符合标准要求	

51	GX-B1310/21-1-26014	2026/2/10	符合标准要求	
52	GX-B1310/21-1-26015	2026/2/10	符合标准要求	

53	GX-B1427/21-1-26016	2026/2/10	符合标准要求	
54	GX-B1310/21-1-26017	2026/2/10	符合标准要求	

55	GX-B1310/21-1-26018	2026/2/10	符合标准要求	
56	GX-B1427/21-1-26019	2026/2/10	符合标准要求	

57	GX-B1328/25-1-26020	2026. 2. 10	本次共检绝缘胶垫50个，50个绝缘胶垫合格。	
----	---------------------	-------------	------------------------	-------------------------------------------------------------------------------------