



序号	报告编号	发布日期	结论	影像资料
155	GX-B1329/21-1-26026~26036	2026. 2. 25	本次共检氧化锌避雷器11组，11组所检项目合格	 A photograph showing a worker in a white hard hat and dark jacket kneeling on the floor in a room filled with rows of white electrical cabinets. A red lightning arrester is connected to the floor with various cables. A date stamp '2026/2/2' is visible in the bottom right corner of the image.
156	GX-B1313/21-1-26024	2026. 2. 25	所检项目合格。	 A photograph showing a worker in a white hard hat and dark jacket kneeling next to a large, grey electrical transformer. A lightning arrester is mounted on top of the transformer. The worker is using a tool to inspect the equipment. A date stamp '2026/2/2' is visible in the bottom right corner of the image.

157	GX-B1451/20-1-26045~26055	2026. 2. 25	柜11台, 11台高压开关柜	
158	GX-B1309/26-1-26004	2026. 2. 25	所检项目合格	

159	GX-B1500/26-1-26024	2026. 2. 25	综合判定：合格		
160	GX-B1500/26-1-26025	2026. 2. 25	综合判定：合格		

161	GX-B1500/26-1-26026	2026. 2. 25	综合判定：合格	
162	GX-B1500/26-1-26027	2026. 2. 25	综合判定：合格	

163	GX-B1611/23-1-26001	2026. 2. 25	所检项目合格		
164	GX-B1611/23-1-26002	2026. 2. 25	所检项目合格		

165	GX-B1611/23-1-26003	2026. 2. 25	所检项目合格	
166	GX-B1611/23-1-26004	2026. 2. 25	所检项目合格	

167	GX-B1303/21-1-26003	2026. 2. 21	综合判定：合格。	
168	GX-B1380/26-1-26009	2026. 2. 21	所检项目合格。	

169	GX-B1598/24-1-26023	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为1.93%，小于5%为正常	
170	GX-B1598/24-1-26024	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为2.21%，小于5%为正常	

171	GX-B1598/24-1-26025	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为2.26%，小于5%为正常	
172	GX-B1598/24-1-26026	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为1.91%，小于5%为正常	

173	GX-B1598/24-1-26027	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为2.30%，小于5%为正常	
174	GX-B1598/24-1-26028	2026. 2. 26	面积损失百分比最大为1.	

175	GX-B1598/24-1-26029	2026. 2. 26	面积损失百分比最大为1.	
176	GX-B1598/24-1-26030	2026. 2. 26	实测钢丝绳有效截面积损失百分比最大为2.08%，小于5%为正常	

177	GX-B1314/21-1-26005~26007	2026. 2. 25	本次共检煤矿在用干式电抗器3台，3台煤矿在用干式电抗器所检项目合格	 <p>2026/1/15</p>
178	GX-B1310/21-1-26028	2026. 2. 24	符合标准要求	 <p>2026/2/8</p>

179	GX-B1310/21-1-26029	2026. 2. 24	符合标准要求	
180	GX-B1310/21-1-26030	2026. 2. 24	符合标准要求	

181	GX-B1310/21-1-26031	2026. 2. 24	符合标准要求	
182	GX-B1310/21-1-26032	2026. 2. 24	符合标准要求	

183	GX-B1310/21-1-26033	2026. 2. 24	符合标准要求	
-----	---------------------	-------------	--------	---