

序号	报告编号	发布日期	结论	影像资料
207	GX-B1328/26-1-26056	2026. 3. 26	本次共检绝缘手套18只，18只绝缘手套合格。	
208	GX-B1328/26-1-26057	2026. 3. 26	本次共检绝缘靴28只，28只绝缘靴合格。	

209	GX-B1328/26-1-26058	2026. 3. 26	本次共检验电器 10支，10支验电器合格 。		
210	GX-B1328/26-1-26059	2026. 3. 26	本次共检便携式接 地和接地短路装置15 套，15套便携式接地 和接地短路装置合格 。		

211	GX-B1328/26-1-26060	2026. 3. 26	本次共检绝缘杆1套, 1套合格。	
212	GX-B1451/26-1-26130~26147	2026. 3. 27	本次共检高压开关柜 18台, 18台高压开关柜 所检项目合格	

213	GX-B1329/26-1-26072~26073	2026. 3. 27	本次共检氧化锌避雷器2组, 2组所检项目合格	 <p>2026/2/23</p>
214	GX-B1350/21-1-26013	2026. 3. 27	本次共检接地装置7处, 7处所检项目合格	 <p>2026/2/24</p>

215	GX-B1322/26-1-26155~26161	2026. 3. 27	本次共检验电力电缆7条，7条所检项目合格		 <p>2026/2/23</p>	
216	GX-B1322/26-1-26162~26166	2026. 3. 27	本次共检验电力电缆5条，5条所检项目合格		 <p>2026/2/24</p>	

217	GX-B1451/26-1-26148~26164	2026. 3. 27	本次共检高压开关柜 17台, 17台高压开关柜 所检项目合格	 <p>2026/2/24</p>
218	GX-B1598/24-1-26078	2026. 3. 27	实测钢丝绳有效截面 积损失百分比最大为 3.40%，小于5%为正常 。	 <p>2026.3.1</p>

219	GX-B1598/24-1-26079	2026. 3. 27	实测钢丝绳有效截面积损失百分比最大为3.45%，小于5%为正常	
220	GX-B1598/24-1-26080	2026. 3. 27	实测钢丝绳有效截面积损失百分比最大为2.72%，小于5%为正常	

221	GX-B1598/24-1-26081	2026. 3. 27	实测钢丝绳有效截面积损失百分比最大为2.96%，小于5%为正常	
222	GX-B1354/26-1-26001	2026. 3. 30	合格	

223	GX-B1322/26-1-26144~26154	2026. 3. 30	本次共检验电力电缆 11条，11条所检项目合格	 <p>2026/03/11</p>
224	GX-B1520/26-1-26008	2026. 3. 30	综合判定：合格。	 <p>2026.3.14</p>

225	GX-B1322/26-1-26203~26207	2026. 3. 30	本次共检验电力电缆5条，5条所检项目合格。 。		 <p>2026.3.13</p>
226	GX-B1322/26-1-26208~26216	2026. 3. 30	本次共检验电力电缆9条，9条所检项目合格。 。		 <p>2026.3.12</p>

227	GX-B1322/26-1-26176~26184	2026. 3. 30	本次共检验电力电缆9条，9条所检项目合格。 。	
228	GX-B1520/26-1-26009	2026. 3. 30	综合判定：合格。	


229	GX-B1322/26-1-26185~26193	2026. 3. 30	本次共检验电力电缆9条，9条所检项目合格。 。	
230	GX-B1322/26-1-26167~26175	2026. 3. 30	本次共检验电力电缆9条，9条所检项目合格。 。	

231	GX-B1322/26-1-26200~26202	2026. 3. 30	本次共检验电力电缆3条，3条所检项目合格。	 <p>2026.3.13</p>
232	GX-B1324/26-1-26010~26011	2026. 3. 30	所检项目合格。	 <p>2026.3.4</p>

233	GX-B1324/26-1-26012~26013	2026. 3. 30	所检项目合格。		
234	GX-B1611/23-1-26005	2026. 3. 31	所检项目合格		

235	GX-B1309/26-1-26007	2026. 3. 31	所检项目合格	
236	GX-B1500/26-1-26036	2026. 3. 31	综合判定：合格	

237	GX-B1500/26-1-26037	2026. 3. 31	综合判定：合格	
238	GX-B1500/26-1-26038	2026. 3. 31	综合判定：合格	

239	GX-B1307/26-1-26003	2026. 3. 31	综合判定：合格。	
-----	---------------------	-------------	----------	---