

序号	报告编号	发布日期	结论	影像资料
1	GX-B1612/23-2-26004	2026. 4. 1	所检项目合格。	 A composite image. The left portion shows a yellow truck at a construction site with a worker in a red hard hat. The right portion is a close-up of a man with glasses and a grey jacket. A date stamp '2026/08/17' is visible in the bottom right corner of the image.
2	GX-B1304/26-2-26022	2026. 4. 1	综合判定：合格。	 A photograph of a large industrial machine in a factory setting. A date stamp '03月 02 2026.03.02 星期一' is visible in the bottom left corner of the image.

3	GX-B1451/26-2-26473~26484	2026/4/1	所检项目合格。	
4	GX-B1451/26-2-26485~26491	2026/4/1	所检项目合格。	



5	GX-B1451/26-2-26492~26495	2026/4/1	所检项目合格。	
6	GX-B1451/26-2-26496~26500	2026/4/1	所检项目合格。	

7	GX-B1451/26-2-26501~26506	2026/4/1	所检项目合格。	 <p>2026/3/8</p>
8	GX-B1322/26-2-26188~26193	2026/4/1	所检项目合格。	 <p>2026/3/5</p>

9	GX-B1322/26-2-26194~26200	2026/4/1	所检项目合格。	 A worker in a white uniform and red helmet is kneeling on a wooden floor, working on a control panel. He is using a multimeter to test the wiring. The date 2026/3/6 is visible in the bottom right corner of the photo.
10	GX-B1322/26-2-26201~26206	2026/4/1	所检项目合格。	 A worker in a blue and orange uniform and red helmet is standing in a control room, working on a control panel. He is wearing a blue face mask. The date 2026/3/6 is visible in the bottom right corner of the photo.



11	GX-B1322/26-2-26207~26211	2026/4/1	所检项目合格。	
12	GX-B1322/26-2-26212~26219	2026/4/1	所检项目合格。	

13	GX-B1329/26-2-26089~26102	2026/4/1	所检项目合格。	
14	GX-B1329/26-2-26103~26117	2026/4/1	所检项目合格。	



15	GX-B1329/26-2-26118~26121	2026/4/1	所检项目合格。	
16	GX-B1324/26-2-26021~26024	2026/4/1	所检项目合格。	

17	GX-B1350/21-2-26024	2026/4/1	所检项目合格。	
18	GX-B1451/26-2-26278~26279	2026/4/1	所检项目合格。	

19	GX-B1451/26-2-26280	2026/4/1	所检项目合格。		
20	GX-B1451/26-2-26281~26298	2026/4/1	所检项目合格。		

21	GX-B1350/21-2-26025	2026/4/1	所检项目合格。	 <p>2026/3/4</p>
22	GX-B1307/26-2-26017	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍（即1.06MPa~1.19MPa）的压力释放装置。</p> <p>综合判定：合格。</p>	 <p>2026/03/12</p>

23	GX-B1307/26-2-26018	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍(即1.06MPa~1.19MPa)的压力释放装置。</p> <p>综合判定：合格。</p>	
24	GX-B1307/26-2-26019	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍(即1.06MPa~1.19MPa)的压力释放装置。</p> <p>综合判定：合格。</p>	

25	GX-B1307/26-2-26020	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍(即1.06MPa~1.19MPa)的压力释放装置。</p> <p>综合判定：合格。</p>	
26	GX-B1307/26-2-26021	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍(即1.00MPa~1.12MPa)的压力释放装置。</p>	

27	GX-B1307/26-2-26022	2026. 4. 1	<p>问题：压力释放装置释放压力不符合规定。</p> <p>建议：更换释放压力为空气压缩机最高工作压力的1.25~1.4倍(即1.00MPa~1.12MPa)的压力释放装置。</p>	
28	GX-B1322/26-2-26224~26245	2026. 4. 1	<p>本次共检验电力电缆22条，22条所检项目合格。</p>	

29	GX-B1322/26-2-26246~26250	2026. 4. 1	本次共检验电力电缆5条，5条所检项目合格。	
30	GX-B1304/26-2-26018	2026. 4. 2	综合判定：合格。	

31	GX-B1304/26-2-26017	2026. 4. 2	综合判定：合格。	
32	GX-B1313/26-2-26111~26112	2026. 4. 1	本次共检电力变压器2台，2台所检项目合格。 。	

33	GX-B1313/26-2-26113~26114	2026. 4. 1	本次共检电力变压器2台，2台所检项目合格。 。	
34	GX-B1313/26-2-26175~26181	2026. 4. 1	本次共检电力变压器7台，7台所检项目合格。 。	

35	GX-B1313/26-2-26173~26174	2026. 4. 1	本次共检电力变压器2台，2台所检项目合格。		
36	GX-B1380/26-2-26015	2026. 4. 1	所检项目合格。		

37	GX-B1313/26-2-26205~26207	2026. 4. 1	本次共检电力变压器3台，3台所检项目合格。	 <p>03月 12 2026.03.12 星期四</p>
38	GX-B1612/23-2-26005	2026. 4. 1	所检项目合格。	 <p>2026/03/18</p>

39	GX-B1612/23-2-26006	2026. 4. 1	所检项目合格。	
40	GX-B1612/23-2-26007	2026. 4. 1	所检项目合格。	

41	GX-B1612/23-2-26008	2026. 4. 1	所检项目合格。	 <p>2026/03/18</p>
42	GX-B1451/26-2-26641~26651	2026. 4. 3	本次共检高压开关柜 11台，11台高压开关柜 所检项目合格。	 <p>03月 04 2026.03.04 星期三 福建省龙岩市上杭县旧县镇</p>

43	GX-B1451/26-2-26652~26656	2026. 4. 3	本次共检高压开关柜5台，5台高压开关柜所检项目合格。	
44	GX-B1451/26-2-26657~26662	2026. 4. 3	本次共检高压开关柜6台，6台高压开关柜所检项目合格。	

45	GX-B1451/26-2-26663~26667	2026. 4. 3	本次共检高压开关柜5台，5台高压开关柜所检项目合格。	
46	GX-B1380/26-2-26016	2026/4/3	所检项目合格。	

47	GX-B1380/26-2-26017	2026/4/3	所检项目合格。	
48	GX-B1380/26-2-26018	2026/4/3	所检项目合格。	

49	GX-B1380/26-2-26019	2026/4/3	所检项目合格。	
50	GX-B1380/26-2-26020	2026/4/3	所检项目合格。	

51	GX-B1303/26-2-26002	2026/4/7	综合判定：合格。	
52	GX-B1300/26-2-26002	2026/4/7	综合判定：合格。	