

序号	报告编号	发布日期	结论	影像资料
217	GX-B1328/26-6-26057	2026/3/26	本次共检绝缘手套 2只, 2只绝缘手套合格。 。	 <p>2026 03 21</p>
218	GX-B1328/26-6-26058	2026/3/26	本次共检全橡胶绝缘 胶靴2只, 2只全橡胶 绝缘胶靴合格。	 <p>2026 03 21</p>

219	GX-B1328/26-6-26059	2026/3/26	本次共检验电器1支， 1支验电器合格。	
220	GX-B1328/26-6-26060	2026/3/26	本次共检便携式接地和接 地短路装置1套，1套携带 式接地和接地短路装置合 格。	

221	GX-B1328/26-6-26061	2026/3/26	本次共检验绝缘胶垫 1块, 1块绝缘胶垫所检项目合格。	 <p>2026 03 21</p>
222	GX-B1451/26-6-26072	2026/3/25	本次共检高压开关柜 1台, 1台高压开关柜所检项目合格。	 <p>2026 03 21</p>


223	GX-B1313/26-6-26019	2026/3/25	本次共检电力变压器1台，1台电力变压器所检项目合格。	 <p>2026 03 21</p>
224	GX-B1322/26-6-26020	2026/3/26	本次共检电力电缆1条，1条电力电缆所检项目合格。	 <p>2026 03 21</p>

225	GX-B1451/26-6-26073~26081	2026/3/25	本次共检高压开关柜9台，9台高压开关柜所检项目合格。	
226	GX-B1451/26-6-26073~26081	2026/3/23	本次共检高压开关柜9台，9台高压开关柜所检项目合格。	

227	GX-B1350/26-6-26004	2026/3/25	本次共检接地装置 2处，2处接地装置所 检项目合格。	 A close-up photograph of a worker wearing a red safety helmet and a grey work jacket with '中檢公信' (Zhongjian Gongxin) written on it. The worker is focused on a task involving electrical wires and a small device. A timestamp '2026-03-25' is visible in the bottom right corner of the image.
228	GX-B1313/26-6-26020~26022	2026/3/25	本次共检电力变压器3 台，3台电力变压器所 检项目合格。	 A photograph of a worker in a grey uniform and red helmet standing in an industrial setting. The worker is pointing towards a large piece of equipment, likely a power transformer, which is surrounded by a bed of white gravel. A timestamp '2026-03-25' is visible in the bottom right corner of the image.

229	GX-B1522/20-6-26001	2026. 3. 25	所检项目合格。	
230	GX-B1522/20-6-26002	2026. 3. 25	所检项目合格。	

231	GX-B1310/21-6-26029	2026. 3. 25	符合标准要求	 <p>2026 02 26</p>
232	GX-B1305/26-6-26009	2026. 3. 25	综合判定：合格。	 <p>2026 03 06</p>

233	GX-B1322/26-6-26021~26026	2026/3/26	本次共检验电力电缆 6条，6条电力电缆所 检项目合格。	
-----	---------------------------	-----------	-----------------------------------	---