







序号	报告编号	发布日期	结论	影像资料
208	GX-B1499/26-P-26001	2026. 4. 21	所检项目合格	 <p>贵州大方煤业有限公司 2026.03.07</p>
209	GX-B1499/26-P-26002	2026. 4. 21	所检项目合格	 <p>贵州大方煤业有限公司 2026.03.07</p>

210	GX-B1499/26-P-26003	2026. 4. 21	所检项目合格	 <p>贵州大方铝业 2026 03 07</p>
211	GX-B1499/26-P-26004	2026. 4. 21	所检项目合格	 <p>贵州大方铝业 2026 03 07</p>

212	GX-B1404/26-P-26003	2026. 4. 23	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T14549-1993 《电能质量 公用电网谐波》要求。</p>	 <p>贵州大方煤业有限公司 2026年3月1日</p>
213	GX-B1404/26-P-26004	2026. 4. 23	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T14549-1993 《电能质量 公用电网谐波》要求。</p>	 <p>贵州大方煤业有限公司 2026年3月2日</p>

214	GX-B1354/26-P-26004	2026. 4. 23	合格。	 <p>贵州大方煤业有限公司 2026年3月1日</p>
215	GX-B1573/26-P-26021	2026. 4. 28	综合判定：合格。	

216	GX-B1308/26-P-26002	2026. 4. 28	陆帅、董金华	 <p>神木市聚隆矿业有限公司 2026/4/16</p>
217	GX-B1350/21-P-26004	2026. 4. 13	本次共检接地装置 8处，8处接地装置所检 项目合格。	 <p>2026/3/20</p>

218	GX-B1350/21-P-26005	2026. 4. 13	本次共检接地装置 6处，6处接地装置所检 项目合格。	
219	GX-B1350/21-P-26006	2026. 4. 13	本次共检接地装置 4处，4处接地装置所检 项目合格。	

220	GX-B1350/21-P-26007	2026. 4. 13	本次共检接地装置 6处，6处接地装置所检 项目合格。	
221	GX-B1322/26-P-26202~26212	2026. 4. 13	本次共检电力电缆 11条，11条电力电缆所 检项目合格。	

222	GX-B1322/26-P-26194~26201	2026. 4. 13	<p>本次共检电力电缆 8条，8条电力电缆所检 项目合格。</p>	 <p>招远市姜家窑金矿有限公司 2026年3月25日</p>
223	GX-B1322/26-P-26172~26180	2026. 4. 13	<p>本次共检电力电缆 9条，9条电力电缆所检 项目合格。</p>	 <p>招远市姜家窑金矿有限公司 2026年3月25日</p>

224	GX-B1322/26-P-26190~26193	2026. 4. 13	本次共检电力电缆 4条，4条电力电缆所检 项目合格。	 <p>招远市姜家窑金矿有限公司 2026年3月24日</p>
225	GX-B1322/26-P-26181~26189	2026. 4. 13	本次共检电力电缆 9条，9条电力电缆所检 项目合格。	 <p>招远市姜家窑金矿有限公司 2026年3月23日</p>

226	GX-B1451/26-P-26392~26398	2026. 4. 28	本次共检高压开关柜7台, 7台高压开关柜所检项目合格。	
227	GX-B1451/26-P-26399~26406	2026. 4. 14	本次共检高压开关柜8台, 8台高压开关柜所检项目合格。	

228	GX-B1451/26-P-26407~26413	2026. 4. 14	本次共检高压开关柜7台, 7台高压开关柜所检项目合格。	 A photograph showing three workers in orange safety suits and red hard hats inspecting high-voltage switchgear in a control room. One worker is holding a clipboard. The date stamp '2026/3/26' is visible in the bottom right corner.
229	GX-B1451/26-P-26414~26422	2026. 4. 14	本次共检高压开关柜9台, 9台高压开关柜所检项目合格。	 A photograph showing two workers in orange safety suits and red hard hats inspecting high-voltage switchgear in a tunnel. One worker is standing in the foreground, and another is in the background. The date stamp '2026/3/26' is visible in the bottom right corner.

230	GX-B1451/26-P-26423~26438	2026. 4. 14	本次共检高压开关柜16台, 16台高压开关柜所检项目合格。	
231	GX-B1451/26-P-26439~26440	2026. 4. 14	本次共检高压开关柜2台, 2台高压开关柜所检项目合格。	

232	GX-B1451/26-P-26441	2026. 4. 14	本次共检高压开关柜1台, 1台高压开关柜所检项目合格。	
233	GX-B1495/26-P-26601~26611	2026. 4. 29	本次共检防爆型高压配电装置11台, 11台防爆型高压配电装置所检项目合格。	

234	GX-B1321/26-P-26250~26251	2026. 4. 29	本次共检电力电缆 2条，2条电力电缆所检 项目合格。	 <p>神木市聚隆矿业有限公司 2026.4.17</p>
235	GX-B1310/21-P-26094	2026. 4. 29	符合标准要求。	 <p>神木市聚隆矿业有限公司 2026.04.16</p>

236	GX-B1312/26-P-26126~26132	2026. 4. 29	本次共检煤矿用防爆干式变压器7台，7台煤矿用防爆干式变压器所检项目合格。	 <p>神木市聚源矿业有限公司 2026.4.17</p>
237	GX-B1312/26-P-26162~26170	2026. 4. 29	本次共检煤矿用防爆干式变压器9台，9台煤矿用防爆干式变压器所检项目合格。	 <p>内蒙古能源集团富民煤炭有限责任公司 2026.04.12</p>

238	GX-B1312/26-P-26155~26161	2026. 4. 29	本次共检煤矿用防爆干式变压器7台，7台煤矿用防爆干式变压器所检项目合格。	
239	GX-B1495/26-P-26509~26518	2026. 4. 29	本次共检防爆型高压配电装置10台，10台防爆型高压配电装置所检项目合格。	

240	GX-B1495/26-P-26519~26530	2026. 4. 29	本次共检高压开关设备12台，12台高压开关设备所检项目合格。	 <p>府谷县瑞丰煤矿有限公司 2026年4月14日</p>
241	GX-B1322/26-P-26241	2026. 4. 28	所检项目合格。	 <p>招远市姜家窑金矿有限公司 2026年3月21日</p>

242	GX-B1322/26-P-26242~26249	2026. 4. 28	本次共检电力电缆 8条，8条电力电缆所检 项目合格。	 <p>招远市姜家窑金矿有限公司 2026年3月27日</p>
243	GX-B1328/26-P-26072	2026. 4. 21	本次共检绝缘手套 40只，40只绝缘手套合 格。	 <p>2026.3.21</p>


244	GX-B1328/26-P-26073	2026. 4. 21	本次共检绝缘靴40只， 40只绝缘靴合格。	 <p>2026.3.21</p>
245	GX-B1328/26-P-26075	2026. 4. 21	本次共检验电器20支， 20支验电器合格。	 <p>2026.3.21</p>

246	GX-B1328/26-P-26076	2026. 4. 21	本次共检携带式接地和接地短路装置20组，20组携带式接地和接地短路装置合格。		 <p>2026.3.21</p>	
247	GX-B1328/26-P-26077	2026. 4. 21	本次共检绝缘杆2组，2组绝缘杆合格。		 <p>2026.3.21</p>	

248	GX-B1328/26-P-26078	2026. 4. 21	本次共检绝缘胶垫 20件，20件绝缘胶垫合格。		 <p>2026.3.21</p>	
249	GX-B1308/26-P-26003	2026. 4. 30	综合判定：合格。		 <p>烟台泰来电气有限公司 2026.4.15</p>	

250	GX-B1499/26-P-26012	2026. 4. 30	所检项目合格。	 <p>横山县天云机械有限公司 2026.4.18</p>
251	GX-B1499/26-P-26013	2026. 4. 30	所检项目合格。	 <p>横山县天云机械有限公司 2026.4.18</p>

252	GX-B1499/26-P-26014	2026. 4. 30	所检项目合格。	 <p>榆山云天云煤矿有限公司 2026.4.18</p>
253	GX-B1573/26-P-26018	2026. 4. 30	综合判定：合格。	 <p>内蒙古昊盛煤业有限公司 2026.4.19</p>

254	GX-B1573/26-P-26022	2026. 4. 30	综合判定：合格。	
-----	---------------------	-------------	----------	---