

序号	报告编号	发布日期	结论	影像资料
246	GX-B1303/26-1-26019	2026. 5. 27	所检项目合格	
247	GX-B1323/26-1-26040~26042	2026. 5. 27	所检项目合格	


248	GX-B1310/21-1-26196	2026. 5. 28	符合标准要求		
249	GX-B1310/21-1-26197	2026. 5. 28	符合标准要求		

250	GX-B1310/21-1-26198	2026. 5. 28	符合标准要求	 <p>2026/4/13</p>
251	GX-B1428/21-1-26195	2026. 5. 20	无缺陷迹痕显示	 <p>2026/4/18</p>

252	GX-B1305/26-1-26015	2026. 5. 29	综合判定：合格	
253	GX-B1404/26-1-26003	2026. 5. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求	

254	GX-B1404/26-1-26004	2026. 5. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求	 <p>2026/3/30</p>
255	GX-B1404/26-1-26005	2026. 5. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求	 <p>2026/3/31</p>

256	GX-B1404/26-1-26006	2026. 5. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求	
257	GX-B1404/26-1-26007	2026. 5. 29	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求	

258	GX-B1305/26-1-26016	2026. 5. 29	综合判定：合格	
259	GX-B1305/26-1-26017	2026. 5. 29	综合判定：合格	